



Jim Doyle, Governor  
Mary P. Burke, Secretary

April 30, 2007

CHICAGO FAUCET CO.  
ENGINEERING  
LARRY HIMMELBLAU  
2100 S CLEARWATER DRIVE  
DES PLAINES IL 60018

Re: Description: SHOWER, HAND-HELD - ASSE 1014  
Manufacturer: CHICAGO FAUCET CO.  
Product Name: NONE  
Model Number(s): 150\*\*\*\*, 151\*\*\*\* AND 153\*\*\*\* ASTERISKS DENOTE NUMBERS OR LETTERS OF  
VARIATIONS WHICH DO NOT CHANGE THE APPROVED OPERATION OF THE BASE  
MODEL  
NUMBERS SHOWN.  
Product File No: 20070092

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This approval supersedes the approval issued on July 30 , 2002, under product file number 20020294.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020294.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with a vacuum breaker conforming to ASSE standard 1001, 1014 or 1011.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wisconsin.gov